Schedule 2 – *Occupier's* statement[1]

Name of building and address:	**10 King Street Caboolture, Qld 4510**		
Prescribed fire safety installation[2]	**Nominated Australian Standard or relevant *maintenance* requirements**[3]	**Was a *critical defect notice*[4] issued during the period covered by this statement (Yes/No)**	**Date of rectification of *critical defect*[4]**
Emergency lighting	AS 2293		
Exit signs	AS 2293		
Fire Detection and Alarm System	AS 1851		
Fire extinguishers	AS 1851		
Fire Hose Reels	AS 1851		
Fire Hydrants	AS 1851	Yes	September 18th, 2026
Fire Sprinklers	AS 1851		
Fire Doors	AS 1851		
Penetration through Fire Rated Structures	AS 1851		

I BRETT MULLER as an authorised person on behalf of **Caboolture Partnership Pty Ltd** declare the above listed *prescribed fire safety installations* have been *maintained* during the period covered by this statement in accordance with this code and as specified,

Sign: _____ **Date:** 14 / 10 / 26.

1. This yearly statement must be kept with the building's *maintenance records* in accordance with A2(c) and be produced on demand by local government officers and authorised officers of the Queensland Fire and Rescue Service.
2. Note: delete *prescribed fire safety installations* that are not installed in/for the building.
3. For example, in accordance with manufacturer's instruction manual date day/month/year or in accordance with the building's *certificate of classification*.
4. Copies of *critical defect notices* issued and proof of rectification within the period of this statement must be attached.
5. This is also known as sound systems and intercommunication systems for emergency purposes.
6. Includes additional *fire safety installations* or conditions that are *required* under the building's *alternative solution* of the *Building Act 1975* or *BCA* clauses E1.10 and E2.3.
7. If the owner is signing or the *occupier* is not employed by a body corporate the 'name of organisation' section does not need to be completed.